

FIRE PROTECTION SITE PLAN

Scale: NTS

1. ALL UNDERGROUND PIPING, VALVING AND EQUIPMENT IS BY-OTHERS - NOT PROVIDED OR INSTALLED UNDER THIS CONTRACT.



FIRE PUMP INFORMATION

ELECTRIC PUMP - 1000 GPM AT 115 PSI RATING
WITH POWER TRANSFER SWITCH - CONTROLLER
JOCKEY PUMP AND ALL NECESSARY DEVICES.

FIRE PUMP - DIAGRAM

Scale: NTS

1. ALL PIPING AND VALVING SHALL BE SIZED IN ACCORDANCE WITH THE APPROPRIATE NFPA STANDARDS AND BY HYDRAULIC CALCULATIONS.
2. SEE FP2 - BASEMENT FIRE PROTECTION PLAN FOR ALL PIPE EXITING THE FIRE PUMP.

GENERAL NOTES

1. The Sprinkler System is designed in accordance with the requirements of NFPA-13, and local authority having jurisdiction.
2. All material shall be UL or FM Listed .
3. Threaded pipe to be black steel Schedule 40. Grooved pipe to be black Sch.40, with welded outlets and grooved fittings.
4. All work to be tested at 200 PSI for 2 Hours.
5. Hangers to be per Details on drawings and per NFPA #13. Hangers to be spaced in accordance with NFPA-13 requirements.
6. Sprinkler Heads to be per NFPA #13 and as shown on legend.
7. All construction is of non-combustible materials. Floors are concrete with concrete and steel support members.
8. Welded pipe to be in accordance with the latest edition of NFPA #13.
9. The owner is responsible for maintaining the proper operating condition of his system(s) and devices.
10. All electrical control and/or alarm system wiring to be provided & installed by others.
11. Heat shall be provided by others to prevent water filled pipe from freezing.
12. All underground shall be By-Others.

REVISIONS

SPRINKLER LEGEND & SCHEDULE

SYMBOL	PART NO./OEM	MFG.	MODEL	TYPE	ORIFICE	K-FACTOR	SPRINKLER COVERAGE	TEMP	HEAD FINISH	SPRINKLER WRENCH	QUANTITY