



ADDENDUM #2

PROJECT: “P” Street WTP Improvements

DATE: 4/25/2024

Receipt of all addenda must be acknowledged on the Bid Form, failure to do so may deem your quote non-responsive.

The following information is listed below:

Contractor Questions

1. *Is there a domestic iron and steel requirement for the project?*
 - a. **There are no domestic iron and steel requirements.**
2. *There are several plans that have been excluded from this project including the plan sheets featuring the buried portion of raw water line. Is the contractor responsible for any portion of the buried raw water line? If so, to what extent should the line be quoted? If not, what is the line of delineation between this phase and the buried line?*
 - a. **The water line is constructed below grade from the well to the southeast corner of the existing tank. The contractor will be required to bring the pipe above grade and complete the rest of the piping on the tank. There may be a short section of buried pipe with two (2) MJ 90-degree elbows.**
 - b. **Contractor shall satisfy itself regarding the location of the existing water line for connection.**

End of Addendum #2.