

# ADDENDUM

ADDENDUM NO: 06

BID PACKAGE NO: N/A

PROJECT: 2023 – Brownsburg HS Fieldhouse Addition and Renovations

PROJECT NO: 2022003

DATE: 05/24/2023

BY: Emery H. M. Hunt

This Addendum is issued in accordance with the provisions of "The General Conditions of the Contract for Construction," Article 1, "Contract Documents" and becomes a part of the Contract Documents as provided therein. This Addendum includes:

## ATTACHMENTS

CSO Addendum No.1 Cover Page, pages 1 through 2

Specifications:

Drawings:

## PART 1 - GENERAL INFORMATION

- 1.1 See attached CAD file for site/civil information. Information for reference only

## PART 2 - BIDDING REQUIREMENTS

- 2.1 NOT USED

## PART 3 - SPECIFICATIONS

- 3.1 08 71 00 – DOOR HARDWARE

A. Hardware Sets: 07, 10, 11

1. Revise office/entry lock catalog number from ~~L9050BDC 17A L583-363 L283-722~~ to **L9056BDC 17A L583-363 L283-722**

B. Hardware Set: 40

1. Revise panic hardware catalog number from ~~LD-99-L-2-17-SNB~~ to **LD-99-L-17-SNB (INSTALL NL DRIVE PIN)**
2. Revise permanent core quantity from ~~2~~, to **1**
3. Revise Rim Cyl Housing quantity from ~~2~~, to **1**

C. Hardware Sets: 42, 43

1. Revise Elec Panic Hardware catalog number from LX-RX-QEL-99-DT 24 VDC to **LX-RX-QEL-99-L-DT-17 24 VDC**

D. Hardware Sets: 48, 62

1. Revise Panic Hardware catalog number from ~~LD-99-L-2-17-SNB~~ to **LD-99-L-17-SNB (INSTALL NL DRIVE PIN)**

2. Revise Permanent Core quantity from ~~5~~ to **3**
  3. Revise Rim Cyl Housing quantity from ~~4~~ to **2**
- E. Hardware Set: 63
1. Revise Panic Hardware catalog number from ~~LD-9927-L-2-LBR-17-SNB~~ to **LD-9927-L-LBR-17-SNB**
  2. Revise Permanent Core quantity from ~~4~~ to **2**
  3. Revise Rim Cyl Housing quantity from ~~4~~ to **2**

#### **PART 4 - DRAWINGS**

- 4.1 NOT USED

#### **PART 5 - QUESTIONS AND ANSWERS**

- 5.1 Is it acceptable to provide a manufacturer's standard warranty in lieu of the specified 25 year warranty for the hydrotherapy tub?
- A. Yes, a manufacturer's standard warranty of 1-year for all parts and labor and a 5-year structural warranty

**END ADDENDUM**



11787 Lantern Road,  
Suite 100  
Fishers, IN 46038  
317.577.0007  
317.577.0286 fax  
[www.meyer-najem.com](http://www.meyer-najem.com)

May 24, 2023

RE: Brownsburg C.S.C. - Brownsburg H.S. Fieldhouse Addition & Renovation  
Addendum 6 CAD Files

Should you wish to receive the CAD files included in addendum 6, please email Amy Meyers ([ameyers@meyer-najem.com](mailto:ameyers@meyer-najem.com)) or Ron Lubbehusen ([rlubbehusen@meyer-najem.com](mailto:rlubbehusen@meyer-najem.com)). CAD files will be emailed to you.

Thank You,  
Amy Meyers  
Preconstruction/Operations Coordinator  
Tel: 317.577.0007 x 163  
Fax: 317.577.0286  
Cell: 317.457.6762  
[www.meyer-najem.com](http://www.meyer-najem.com)