

# ADDENDUM



OWNER

**IVY TECH COMMUNITY COLLEGE**

PROJECT

**GLICK TECHNOLOGY CENTER MECHANICAL  
UPGRADES**

A/E Project 5-6319

PURPOSE

**ADDENDUM 002**

THIS ADDENDUM SHALL FORM PART OF THE  
BIDDING DOCUMENTS. CHANGES, ADDITIONS,  
CLARIFICATIONS OR DELETIONS HEREIN  
SUPERSEDE THE DRAWINGS AND  
SPECIFICATIONS. BIDDERS SHALL INCLUDE ON  
THE PROPOSAL FORM ACKNOWLEDGEMENT OF  
THE RECEIPT OF THIS ADDENDUM.

ATTACHMENTS

**General: Existing MAU-2 schedule**

ARCHITECT-ENGINEER

**GMB**

[www.gmb.com](http://www.gmb.com)

616.796.0200

# ADDENDUM



## **GENERAL**

### ITEM NO. 1      QUESTIONS & ANSWERS

Q1: What is the existing makeup air?

A1: Refer to attached Existing MAU-2 schedule.

Q2: Regarding Controls, how does the exhaust fan tie into the makeup air unit?

A2: UNIT SHALL BE INTERLOCKED WITH TWO EXISTING EXHAUST AIR FANS REF#4 & REF#5 TO OPERATE WHEN EITHER FAN (REF#4 OR REF#5) IS "ON". PROVIDE AND INSTALL ALL REQUIRED LABOR AND PARTS. THE CONTRACTOR IS RESPONSIBLE TO CONFIRM PROPER OPERATION OF EXISTING MOTORIZED DAMPER AT RELIEF AIR LOUVER IN HVAC LAB (ROOM B-121) SERVED BY MAU-2, REF#4 & REF#5. (Refer to note on M1.01)

### ITEM NO. 2      EXISTING MAU-2 SCHEDULE (**NEW**)

## G A S F I R E D M A K E - U P A I R U N I T S C H E D U L E

[illegible]

NOTES:

1. PROVIDE ELECTRONIC IGNITION, POWER VENT BURNER AND THRU THE WALL DUCTED COMBUSTION INTAKE AND GAS VENT.
2. MOTOR DATA: 460V-3Ø