## ADDENDUM TWO

Steuben County Jail Roof Replacement - 2024 Steuben County Commission 206 E Gale St Angola, Indiana 46703

MARTINRILEY architects • engineers 221 West Baker Street Fort Wayne, Indiana 46802 260-422-7994

Commission No.: F24001 Addendum Date: April 12, 2024

**Conditions:** The following clarifications, amendments, additions, deletions, revisions and modifications are a part of the contract documents and change the original documents only in the manner and to the extent stated.

Copies of the Addendum shall be bound with all contract sets of drawings and specifications.

Receipt: Addendum Number Two shall be acknowledged by Bidders on their Bid Form.

**CLARIFICATIONS:** The roof membrane shall be non-reinforced 60mil EPDM.

CHANGES TO THE SPECIFICATIONS:  $\ensuremath{\mathsf{N/A}}\xspace$ 

CHANGES TO THE DRAWINGS: N/A

END OF ADDENDUM NUMBER TWO Attachments:

W:\2024 Projects\F24001 Steuben Jail Rf Repl\Project Management\05-Bidding\Addendum Two\Addendum Two.doc