



A D D E N D U M

Project No.: 2301113

Project: East Allen County Schools – Renovation Projects

Addendum No: 1

Date: 04/16/2024

TO: ALL BIDDERS OF RECORD

ADDENDUM NO. 1, to Drawings and Specifications dated 04/03/2024, for the Renovation Projects for the East Allen County Schools; as prepared by ELEVATUS Architecture, 111 E. Wayne Street, Suite 555, Fort Wayne, IN 46802

This ADDENDUM shall hereby be and become a part of the Contract Documents the same as if originally bound thereto.

The following clarifications, amendments, additions, revisions, changes, and modifications change the original Contract Documents only in the amount and to the extent hereinafter specified and set forth in this ADDENDUM.

Each Bidder shall acknowledge receipt of this ADDENDUM on the Bid Form.

PROJECT MANUAL:

ITEM NO. 1.01 - PROJECT MANUAL, 10 21 13.19, SOLID PLASTIC TOILET COMPARTMENTS

- A. Article 2.1, paragraph B; delete subparagraph in its entirety:
 - “1. Accurate Partitions Corp., Lyons, IL.

- B. Article 2.1, paragraph B; revise subparagraph 2 to read as follows:
 - “1. “Hiny Hidders” by Scranton Products, Scranton, PA

Submitted By:

Taryn H. Wilson, AIAS

ELEVATUS
ARCHITECTURE

cc: ☐ File: Document96
☐ Owner:
☐ Contractor:
☐ Consultant:
☐ Consultant:



Primary Engineering, Inc.
2828 Lake Ave.
Fort Wayne, Indiana 46805
260-424-0444 ph
www.primary-eng.com



Addendum: **1**

Date: **04/16/2024**

Project: **EACS Classroom and
Restroom Renovations**

Comm #: **23574**

The following items shall be incorporated into the specifications and drawings and are considered to be integral to the bid documents for the project. Acknowledgement of receipt of this addendum is required on the bid form.

Item #1: Drawing Sheet MP-001 for Leo High School.

- A.** Clarifying that the plumbing fixture schedule for Urinals tagged UR-1 and UR-1H do not need remark #1 as they will be using reused fixture carriers as noted on other sheets.
- B.** Verifying that the water closets are to have new fixture carriers as noted.
- C.** Verifying that the lavatories are to use existing fixture carriers with new support arms as needed for the new fixture.

