

Addendum



NOBLESVILLE
SCHOOLS

ADDENDUM NO: 2

PROJECT: **NOBLESVILLE SCHOOLS – 2024 CAMPUS PAVING IMPROVEMENTS**

CONTEXT PROJECT NO: 24-1777

DATE: 5/8/2024

BY: Cameron Hull

This Addendum is issued in accordance with the provisions of “The General Conditions of the Contract for Construction,” Article 1, “Contract Documents” and becomes a part of the Contract Documents as provided therein. This Addendum includes:

PART 1 – BIDDING AND CONTRACT REQUIREMENTS

A. UNUSED

PART 2 – SPECIFICATIONS

A. UNUSED

PART 3 – DRAWINGS

A. UNUSED

PART 4 – QUESTIONS & ANSWERS

1. **Q: How much recycled asphalt pavement (RAP) is allowed to be used in the pavements?**

A: Recycled material content shall follow INDOT Standard Specifications for RAP usage. INDOT Specifications shall take precedent over 25% maximum RAP limit mentioned in Section 2.2.C of Section 32 12 16 Asphalt Paving.

2. **Q: Can you provide additional clarity on the expected crack filling scope for the project?**

A: Cracks indicated on the plans are 1/2” to 1” cracks along asphalt seams. Contractor shall clean any dirt or debris from cracks via compressed air and/or wire brush and fill with a hot poured joint sealant compliant with INDOT Standard Specifications.

END OF ADDENDUM 2