



Revision / Clarification Letter #03
For Bid Item #01 Site Excavation and Site Utility Work

Date: 07/01/2024

Project:
Westfield Washington School Corporation
Westfield Middle School West (Site Package)
17707 Centennial Road,
Westfield, IN 46074

Owner:
C/O Westfield Washington School Corporation
19500 Tomlinson Road
Westfield, IN 46074

Hagerman Inc.
10315 Allisonville Rd.
Fishers, IN 46038

Hagerman Project No. #23-2170-Q

TO: Bid Item #01 Site Excavation and Site Utility Work Bidders:

Acknowledge receipt of this Revision / Clarification letter in the space provided on the bid form. Failure to acknowledge this Revision / Clarification letter may subject the Bidder to disqualification.

I. REVISIONS / CLARIFICATIONS:

1. Bid Item #01 Site Excavation and Utility Contractor shall furnish and install the storm piping per the Legend D5 on C504, which include the Three (3) D5 storm structures under the Football Field / Soccer Field as shown on C504. These three manholes should be per the Storm Sewer



Manhole Detail 13 on C901. (This also includes the ones shown on C503.) These are the 24" access port buried. Please note the D5 at the top left is not shown but I accounted for it. Also include the storm manhole 799. (which make four (4) storm manholes in the Football / Soccer Field).

2. Bid Item #01 Site Excavation and Utility Contractor shall furnish and install the storm piping per the Legend D6 on C504, which includes the 12" dual wall perforated HDPE perimeter storm drain header piping, which shall include the 375 LF + 200 LF + 375 LF as shown on C504 under the Football Field / Soccer Field. The future turf contractor for the ball field will tie into this header pipe. (This also includes what is shown on C503.)
3. Bid Item #01 Site Excavation and Utility Contractor shall furnish and install the storm piping per the Legend D8, Roof Drain Piping as shown on the Civil Drawings, C501, C502, C503, C504, C505 and the other drawings.