

Addendum 2

Owner Information	INDIANA DEPARTMENT OF ADMINISTRATION
Contractor Information	N/A
DATE	10/25/2024
PROJECT NAME	INDIANA STATE POLICE POST #45 (SELLERSBURG) HVAC RENOVATION
INTROBA PROJECT #	2035.0012551
PUBLIC WORKS PROJECT #	10011020-24-018-C1
PWP CONTRACT #	81780
DISTRIBUTION	Owner
ADDENDUM CONSIST OF	(2) 8.5 X 11 PAGES AND (0) 30X42 FULL-SIZE SHEETS

The following additions, revisions, and modifications are part of the contract documents, which shall be amended accordingly. Acknowledge receipt of addenda on the bid form. Failure to acknowledge receipt of this addendum may result in the rejection of your offer.

SPECIFICATIONS

1. 099123 INTERIOR PAINTING:
 - a. Remove specification in its entirety.
2. 235233 HYDRONIC BOILERS:
 - a. Paragraph 2.1, Subparagraph A., add the following subparagraphs:
 - "3. Cleaver Brooks
 4. Viessmann"

DRAWINGS

1. M400
 - a. Add to Sheet Keynote 5 as follows:

"EXISTING PVC PATHWAY(S) TO REMAIN FOR FUTURE USE."
 - b. Add to Sheet Keynote 9 as follows:

"REMOVE/REBUILD PENETRATION LOCATION NEAR CONDENSING UNITS TO ALLOW FOR INSTALLATION OF NEW COPPER PIPING UNDER DRIVE. FILL/SEAL ANY UNUSED EXISTING PVC PATHWAY(S). UNCLOG/CLEAN PATHWAY DRAIN IN BUILDING AT PIPING PENETRATION LOCATION."

SIGNATURE Christopher Hawk

