



## ADDENDUM NO. 02

2025.01.06

# 02

### FOR:

Evidence Room for  
City of Southgate Police Department  
122 Electric Ave  
Southgate, Kentucky 41071

### PREPARED BY:

**Emboss Design** PSC  
906 Monmouth Street  
Newport Kentucky, 41071  
P: 859.578.6002

---

NOTE: The following additions, deletions, corrections, changes and/or clarifications to the Contract Documents (Drawings) for the above referenced project shall hereby be incorporated into the work described and their effect on the contract cost shall be included in the contractor's bid. Bidders shall verify this fact by indicating receipt of this Addendum in their bids.

### 1.0: GENERAL

- 2.1: As clarification, door 002 on the Door Schedule should be changed to (2)3'-0"X6'-8"+/- doors to correspond to the floor plan
- 2.2: As clarification, all locksets are to be mortised type locksets per the Project Manual, not cylindrical
- 2.3: Changes to glass block specifications:
- a. Sizes smaller than 8x8 are permitted to be used as required to infill opening without modifying existing masonry opening size. Glass block sizes used shall provide minimum number of glass block units needed to infill the opening.
  - b. Glass block shall be inset 1" from exterior face of brick
  - c. 3" thick glass block is permitted
  - d. Installation of the glass block unit in an aluminum channel frame is NOT permitted.
- 2.4: At glass block locations, provide painted (match new wall color paint) 1x trim with ½" radius edge on interior side, full perimeter, to cover newly exposed edge of structural glazed tile. Hold trim back from face of wall to same location as existing quarter round trim. Provide pressure treated blocking if/as required to pad the painted wood trim out to the edge of the glass block if the interior masonry opening is larger than the exterior.
- 2.5: The size of the new exhaust fan in the rear window is not known at this time (Genera Contractor & glass block contractor to coordinate with owner's mechanical contractor. It is the intent that the exhaust fan be located at the upper portion of the window with glass block below. If the fan is small enough to be incorporated within a glass block assembly that fills the entire masonry opening this would be acceptable as well.

**END OF ADDENDUM NO. 2**