

**ADDENDUM ONE**

Fort Wayne Airport  
Hangar 2043 Roof Replacement  
4401 Altitude Drive  
Fort Wayne, IN 46809

**MARTINRILEY** architects ▪ engineers  
221 West Baker Street  
Fort Wayne, Indiana 46802  
260-422-7994

Commission No.: F24091  
Addendum Date: January 31, 2025

**Conditions:** The following clarifications, amendments, additions, deletions, revisions and modifications are a part of the contract documents and change the original documents only in the manner and to the extent stated.

Copies of the Addendum shall be bound with all contract sets of drawings and specifications.

**Receipt:** Addendum Number One shall be acknowledged by Bidders on their Bid Form.

**CLARIFICATIONS:**

Thermoplastic Membrane Sheets shall be installed so long length of sheet is installed parallel to the rake (east and west) ends of roof area <1>. Coordinate with manufacturer other acceptable orientation of membrane sheets should they differ from this clarification.

Install the wood blocking supports for the snow retention system per snow retention manufacturer requirements. All wood blocking shall be properly secured using screws and bolts into structure below.

All existing wood blocking at gutter detail shall be removed to allow new wood blocking to be installed in place.

Questions have come up from contractors that are not certified Sika/Sarnafil installers installing coatings on the existing warranted roofs on roof areas <2> and <3>.

- If the Prime Contractor cannot maintain existing warranties for the Alternate R-1-A coating work on areas <2> and <3>, list in your bid any warranty complications so the Owner may review and consider.
- Contractors bidding with coating that is not the noted "Basis of Design", provide the substitution request showing the product meets or exceeds what is specified including warranty requirements.

**CHANGES TO THE SPECIFICATIONS:**

N/A

**CHANGES TO THE DRAWINGS:**

N/A

**END OF ADDENDUM NUMBER ONE**

Attachments:

N/A

W:\2024 Projects\F24091 FW Aero Center 2043 Hangar Rf Replace\Project Management\05-Bidding\Addendum One\Addendum Master.docx