

**Addendum D1**

re: **NORTHWEST ALLEN COUNTY SCHOOLS**  
 Carroll Middle School Track Reconstruction  
 136034.00

issue date: **February 27, 2025**

This Addendum forms a part of the Contract Documents for the above-referenced project and is issued in accordance with the Instructions to Bidders. Acknowledge receipt of this addendum by inserting its number in the space provided in the bid form.

ITEM	LOCATION	DESCRIPTION
A1.01	BIDDING REQUIREMENTS AND FORMS Contractor’s Qualification Statement (AIA Document A305)	<b><u>DELETE:</u></b> DELETE from the Table of Contents the Contractor’s Qualification Statement (AIA Document A305). Please waive from the bid submission documents and requirements.

**Civil Items:**

C1.01	SPECIFICATIONS Section 321825 Running Track Surface & DRAWING C3.1 <b>(Specification &amp; Drawing NOT reissued)</b>	<b><u>ADD:</u></b> See attached write-up “ADDENDUM NO.1” from A & Z Engineering dated February 27, 2025 for Addendum Items to Specification Section 321825 Running Track Surface and drawing C3.1.
-------	---	---



**Addendum D1**  
**NORTHWEST ALLEN COUNTY SCHOOLS**  
Carroll Middle School Track Reconstruction  
February 27, 2025  
Page 2

<b>ITEM</b>	<b>LOCATION</b>	<b>DESCRIPTION</b>
-------------	-----------------	--------------------

Submitted by:  
**The Moake Park Group, Inc.**



Jeremy M. Ogle, AIA, Principal

**attachments:** Write-up "ADDENDUM NO.1" from A & Z Engineering

**copies:** All Plan Holders  
136034.00/670

**ADDENDUM NO. 1**  
TO  
THE BIDDING REQUIREMENTS AND CONTRACT DOCUMENTS  
FOR  
**CARROLL MIDDLE SCHOOL TRACK RECONSTRUCTION (136034)**  
FOR  
NORTHWEST ALLEN COUNTY SCHOOLS  
Addendum Date: February 27, 2025

---

This Addendum consists of (1) page. Attachments include the following:

None

**ATTENTION BIDDERS**

All plan holders shall carefully read this Addendum and give it consideration in the preparation of their Bid. All Prime Bidders are responsible for informing their appropriate Subcontractor and Material Suppliers of these Addendum items.

Additionally, this is the ONLY NOTIFICATION that plan holders will receive of said Addendum and Bidders MUST ACKNOWLEDGE having received Addenda when submitting a Bid for Consideration. Otherwise, the Bid will be rejected as incomplete.

The following, as additions to and modifications in the Bidding Requirements and Contract Documents, will be included in, and become a part of the Project. This Addendum forms a part of the Contract Documents. Bidders are, therefore, instructed to take the following into account in rendering any Bid for this work.

**ADDENDUM ITEMS**

1. SPECIFICATION SECTION 321825 – RUNNING TRACK SURFACE
  - a. Add Part 2.1, G: Gen-Track GT-4 Track Surface (meeting specification requirements) by Current Surfaces, Inc.
  
2. C3.1 – Concrete Field Event Runway Detail Section C-C
  - a. The porosity inhibiting admixture can be omitted from the concrete mix.