

ADDENDUM NO. 1

Urinals Replacement
Monrovia High School and Monrovia Elementary School

Project No. 223169.02

Index of Contents

Addendum No. 1, 2 items, 1 page
Pre-Bid Clarification Log
Pre-Bid Sign-in Sheet

Date: February 27, 2025

FANNING/HOWEY ASSOCIATES, INC.
ARCHITECTS/ENGINEERS/CONSULTANTS

TO: ALL BIDDERS OF RECORD

ADDENDUM NO. 1 to Drawings and Project Manual, dated February 7, 2025, for Monro-Gregg School District, 135 S. Chestnut Street, Monrovia, Indiana 46157; as prepared by Fanning/Howey Associates, Inc., Indianapolis, Indiana.

This Addendum shall hereby be and become a part of the Contract Documents the same as if originally bound thereto.

The following clarifications, amendments, additions, revisions, changes, and modifications change the original Contract Documents only in the amount and to the extent hereinafter specified in this Addendum.

Each bidder shall acknowledge receipt of this Addendum in his proposal or bid.

NOTE: Bidders are responsible for becoming familiar with every item of this Addendum. (This includes miscellaneous items at the very end of this Addendum.)

RE: ALL BIDDERS

ITEM NO. 1. PROJECT MANUAL, SECTION 22 11 16 – DOMESTIC WATER PIPING

A. Ad Section 2.1.C.1.a., as follows:

“a. Manufacturers: Viega, Nibco, Apollo.”

ITEM NO. 2. PROJECT MANUAL, SECTION 22 40 00 – PLUMBING FIXTURES

A. Add Section 2.1.A.3., as follows:

“3. Carriers: Zurn, Watts, Jay R. Smith”

END OF ADDENDUM

PRE-BID REQUEST FOR INTERPRETATION/CLARIFICATION LOG

RFI#	Date Received	Request for Interpretation Item	Dwg./Spec.	Response
ADDENDUM NO. 1				
1	02-25-25	<p>1. Spec book 22 40 00-3 (N) Provide adjustable urinal carriers to support...This does not list any Manufacturers for the carriers. Can you provide a list of approved carrier Manufacturers for this project? Smith/Zurn?</p> <p>2. Spec Book 22 11 16-1 (C) Piping and fittings shall be joined by crimping process. This does not list any Manufacturers for the press fittings. Can you provide a list of approved copper Press fitting Manufacturers for this project? Viega/NIBCO/APOLLO</p>		<p>1. Provide urinal carrier by Zum, Watts, Jay R Smith as indicated in Addendum No. 1.</p> <p>2. Provide material for crimping process by Viega, Nibco, Apollo as indicated in Addendum No. 1.</p>

Project Name MONROE-GREGG SCHOOL DISTRICT
 URINAL REPLACEMENT PROJECT
 Project No. 223169.02
 Meeting Date FEBRUARY 18, 2025

PLEASE PRINT CLEARLY. YOUR NAME AND
 TITLE WILL BE INCLUDED IN THE MEETING
 REPORT.
 THANK YOU!

SIGN-IN SHEET

NAME (Please print)	TITLE	COMPANY	PHONE/ FAX	E-MAIL
Trent Provo	Superintendent	Monroe-Gregg School District		tprovo@m-gsd.org
Peter Winters	Project Manager	Fanning Howey	317.410.1289	pwinters@fhai.com
Brett Everett	Maintenance Director	M.G.S.D.	317-361-8114	bceverett@m-gsd.org
Shawn Swopes	Maintenance Ass.	M.G.S.D.	317-997-7493	sswopes@m-gsd.org
Justin Calky	PM	HP Legacy	317 522 3425	jcalcky@hplegacyinc.com
ERIKS BERZUPS	Super	HP Legacy	317-997-3437	eberzups@hplegacyinc.com