



People-first places.

WHITLEY COUNTY CONSOLIDATED SCHOOLS
WCCS Northern Heights Elementary Mechanical Renovation-2025 ; DC's #20240001
3/5/2025

ADDENDUM NO. 3

This addendum is issued as a supplement to the plans and specifications and shall be considered an integral part of the same.

Item: **3.01**
Location: Sheets M4.1 Through M4.3
Description: All new equipment including VUV, Cabinet Heaters, Hot water Coils, Terminal Boxes and Blower Coils shall receive new coil packs per appropriate details on M4.3, control valves will be provided by owner. Existing equipment receiving new control valves shall receive new flow controls per detail 6/M4.3 with flows noted on Existing Equipment Flow Schedule on sheet M4.1.

**No revised or updated sheets are being issued with this addendum.*

Each contractor is responsible for incorporating all changes into their bid.

Respectfully submitted,

A handwritten signature in black ink, appearing to read 'Craig Scully'.

Craig Scully, PE, Project Manager
Design Collaborative, Inc.
CSS/KLB