

# Addendum



ADDENDUM NO: 3

PROJECT: **2025 VARSITY FOOTBALL, TRACK, AND FENCING IMPROVEMENTS**

CONTEXT PROJECT NO: 24-1874

DATE: 03/21/2025

BY: Fred Prazeau

This Addendum is issued in accordance with the provisions of "The General Conditions of the Contract for Construction," Article 1, "Contract Documents" and becomes a part of the Contract Documents as provided therein. This Addendum includes:

## **PART 1 – BIDDING AND CONTRACT REQUIREMENTS**

A. UNUSED

## **PART 2 – SPECIFICATIONS**

A. UNUSED

## **PART 3 – DRAWINGS**

B. UNUSED

## **PART 4 – QUESTIONS & ANSWERS**

- Q: Can you clarify the access box to be install in the turf field?**  
*A: Contractor to provide in-ground junction boxes designed for synthetic turf installations such as "Versacom Turf-Box as manufactured by Gill Athletics or equivalent. Provide one (1) 2" PVC conduit with pull string from box to football field play clocks. Coordinate with electrical service provided by others.*

END OF ADDENDUM 3