

Project No. F24108

Fort Wayne, Indiana

ADDENDUM #02

Fort Wayne Community Schools 2025 Masonry Repairs at Wayne H.S. & Snider H.S.
Project M-2
1200 South Clinton Street
Fort Wayne, Indiana 46802

MARTINRILEY architects ▪ engineers
221 West Baker Street
Fort Wayne, Indiana 46802
260-422-7994

Commission No.: F24108 Addendum Date: March 24, 2025

Conditions: The following clarifications, amendments, additions, deletions, revisions and modifications are a part of the contract documents and change the original documents only in the manner and to the extent stated.

Copies of the Addendum shall be bound with all contract sets of drawings and specifications.

Receipt: Addendum Number #02 shall be acknowledged by Bidders on their Bid Form.

CLARIFICATIONS:

- 1) Photos 13/M213 & 14/M213 reference lintel repair detail 15/M213, which calls out for a steel angle L5X4X3/8 to be used for the repair. This angle needs to be changed to L5X3-1/2X1/2.

CHANGES TO THE SPECIFICATIONS: N/A

CHANGES TO THE DRAWINGS: N/A

END OF ADDENDUM NUMBER #02

Attachments: N/A