

**ADDENDUM NO. TWO**

**JOB NAME:** Southport 6<sup>th</sup> Grade Academy & PTEC Chiller Replacement

**PROJECT NUMBER:** 800-69717

**DATE OF ADDENDUM:** 06/18/2025



---

**Dustin Barth, P.E.**  
**Indiana Registration No. 12200401**

**THIS ADDENDUM FORMS A PART OF THE CONTRACT DOCUMENTS AND IS ISSUED IN ACCORDANCE WITH THE INSTRUCTIONS TO BIDDERS. ACKNOWLEDGE RECEIPT OF THIS ADDENDUM BY SIGNING THE ADDENDUM ACKNOWLEDGEMENT SECTION OF YOUR PROPOSAL.**

**GENERAL:**

1. The entire PTEC chilled water system will need to be refilled with 30% Glycol. It will take approximately 2,000 Gallons of 30% Glycol to fill the system.
2. This is not a common construction wage project.

END OF ADDENDUM 2