

Addendum #: 2

KBSO Project #: 24023
Project Name: Noblesville HS AHU Replacements – Bid Pack 3
Issue Date: 7/14/2025

This Addendum number 2 to the drawings and specifications shall supplement, amend, and become a part of the bidding documents, plans, and specifications. All bids and construction contracts shall be based on these modifications to the original contract documents.

Part 1. BIDDING AND CONTRACT DOCUMENTS

1.01 Question and answer:

a. Question:

i. Are there any alternates in this project?

b. Answer:

i. No, there are no alternates. Listed below are the specification adjustments required to remove references to alternates. The intent is as follows:

1. Base bid shall include face and bypass preheat coils for the air handlers, consistent with the AHU schedules and notes.
2. Base bid shall include duct sealing for newly added ductwork, but not the "Aeroseal duct sealing" paragraph. Aeroseal is not required.

Part 2. SPECIFICATIONS

2.01 01 23 00 Alternates – remove entire section without replacement.

2.02 23 31 13 2.4.G Aeroseal Duct Sealant (ALTERNATE BID ONLY):

a. Remove paragraph in its entirety without replacement.

2.03 23 31 13 3.3.C revise to read:

a. All newly installed ducts shall be sealed as listed.

2.04 23 31 13 3.3.C.3 remove in its entirety without replacement.

2.05 23 73 23 2.4.C. Revise paragraph heading to remove "(ALTERNATE BID ONLY)".

Part 3. DRAWINGS

-

ATTACHMENTS:

-

END OF ADDENDUM