

ADDENDUM NO. 2

Southmont High School Boiler and Air Handler Replacement

Southmont Schools
Crawfordsville, Indiana

Project No. 225080.00

Index of Contents

Addendum No. 2, 2 items, 1 page

April 2, 2026

I hereby certify that this Addendum was prepared by me or under my direct supervision and that I am a duly registered Architect/Engineer under the Laws of the State of Indiana.

FANNING/HOWEY ASSOCIATES, INC.
ARCHITECTS/ENGINEERS/CONSULTANTS



Paul A. Miller, License No. AR10800161
Expiration Date: 12/31/2027

TO: ALL BIDDERS OF RECORD

ADDENDUM NO. 2 to Drawings and Project Manual, dated February 27, 2026, for Southmont Schools, 6401 US 231 S., Crawfordsville, Indiana 47933; as prepared by Fanning/Howey Associates, Inc., Indianapolis, Indiana. This Addendum shall hereby be and become a part of the Contract Documents the same as if originally bound thereto.

The following clarifications, amendments, additions, revisions, changes, and modifications change the original Contract Documents only in the amount and to the extent hereinafter specified in this Addendum.

Each bidder shall acknowledge receipt of this Addendum in his proposal or bid.

NOTE: Bidders are responsible for becoming familiar with every item of this Addendum. (This includes miscellaneous items at the very end of this Addendum.)

RE: ALL BIDDERS

ITEM NO. 1. DRAWING SHEET NOS. M-601

- A. AIR HANDLER UNIT SCHEDULE: AHU-G4: Change "BHP" from "5.4" to "(2) 5.4".
- B. AIR HANDLER UNIT SCHEDULE: AHU-G5: Change "BHP" from "5.6" to "(2) 5.4".
- C. AIR HANDLER UNIT SCHEDULE: AHU-G4: Change "HP" from "7.5" to "(2) 7.5".
- D. AIR HANDLER UNIT SCHEDULE: AHU-G5: Change "HP" from "7.5" to "(2) 7.5".

ITEM NO. 2. DRAWING SHEET NO. E-402

- A. AHU-G4 and AHU-G5; change the horsepower from 7.5 HP, to "(2) 7.5 HP".
- B. VFD-AHU-G4 and VFD-AHU-G5; change the keynote P5, to read "P6".

END OF ADDENDUM