

# Addendum



NOBLESVILLE  
SCHOOLS

ADDENDUM NO: 1

PROJECT: **NOBLESVILLE SCHOOLS – 2026 CAMPUS PAVING IMPROVEMENTS**

CONTEXT PROJECT NO: 25-1948

DATE: 02/26/2026

BY: Fred Prazeau

This Addendum is issued in accordance with the provisions of “The General Conditions of the Contract for Construction,” Article 1, “Contract Documents” and becomes a part of the Contract Documents as provided therein. This Addendum includes:

## **PART 1 – BIDDING AND CONTRACT REQUIREMENTS**

A. UNUSED

## **PART 2 – SPECIFICATIONS**

A. UNUSED

## **PART 3 – DRAWINGS**

A. UNUSED

## **PART 4 – QUESTIONS & ANSWERS**

1. **Q: Is existing stone base intended to remain at the High School?**

*A: Yes, existing stone base is anticipated to remain. The Bid Form correctly indicates: “Existing stone base shall remain; regrade, supplement, and compact prior to laying new binder and surface.” Please assume this for the totality of standard-duty and heavy-duty coverage.*

2. **Q: Detail 2/L501 for Heavy-duty Asphalt Pavement shows a full stone base. We discussed reusing existing stone base during the Pre-Bid Meeting. Please clarify.**

*A: Detail 2/L501 is intended for the expanded bus pavement at West Middle School. Bus pavement grows west into an existing greenspace. A full profile is required in that instance. Reusing stone base applies to the High School lots.*

3. **Q: Are existing pavement markings to be restored?**

*A: Replace all High School parking lot and drive markings as currently marked. Apply bus markings at West Middle School as shown in Plans. It’s basically the current bus marking, plus a few bonus bus stalls once the pavement is widened. Offset dimensions of bus stalls are made uniform during the restriping.*

4. **Q: The High School parking lots are drawn with heavy-duty and standard-duty depths in various areas. We believe the lots were built with a uniform profile thickness. If so, how shall we price the replacement of binder and surface?**

*A: Because the profile depths are not definitively known, in the interest of fair bidding, Respondents shall assume 4.5” of binder and 1.5” of surface across the High School lots and drives.*

END OF ADDENDUM 1