

Addendum



ADDENDUM NO: 2

PROJECT: **FISHERS HIGH & JUNIOR HIGH TENNIS RECONSTRUCTION**

CONTEXT PROJECT NO: 25-1914

DATE: 02/27/2026

BY: Fred Prazeau

This Addendum is issued in accordance with the provisions of "The General Conditions of the Contract for Construction," Article 1, "Contract Documents" and becomes a part of the Contract Documents as provided therein. This Addendum includes:

PART 1 – BIDDING AND CONTRACT REQUIREMENTS

A. UNUSED

PART 2 – SPECIFICATIONS

A. UNUSED

PART 3 – DRAWINGS

A. UNUSED

PART 4 – QUESTIONS & ANSWERS

1. Question: We noticed a few Rain Bird sprinkler housings that will need to get relocated at Fishers Junior High. Will this be done by the school or should the contractor include this work in their bid price?
Answer: *HSE facilities will address irrigation modifications.*
2. Question: Should Bidders include monies to restore/fix any damage to the existing basketball court asphalt? There will be a lot of dump trucks, construction equipment and concrete trucks going in and out over the stone that is to be placed over the courts and in our experience they always get damaged.
Answer: *Any areas damaged by staging and/or access in the course of construction shall be restored as part of the Base Bid.*
3. Question: Where will the existing aluminum bleachers be stored?
Answer: *Bleachers can be stored in common areas immediately adjoining the project. Bidders shall coordinate with the Owner during the Pre-Construction Conference to find a mutually agreeable location.*
4. Question: Should the existing waterline to the fountain at the High School actually be capped under the new PT tennis courts? Would you prefer the line be removed in its entirety under the new courts?

Addenda

Answer: *Bidders shall assume the existing fountain water line be removed in its entirety under the PT slab.*

5. Question: Is it permissible to move the High School construction entrance to a different location so that equipment does not need to drive over the newly place retaining wall to access the construction site?

Answer: *The Owner is willing to discuss alternative locations. Any damage caused by staging and/or access during construction shall be restored as part of the Base Bid.*

6. Question: Is orange snow fence an acceptable alternative for tree protection?

Answer: *Yes, orange snow fence is acceptable if properly installed and maintained.*

7. Question: Is there a floor in the High School mini-barn that is to be relocated, or is it sitting directly on a concrete pad?

Answer: *The mini-barns have their own floor.*

8. Question: Is the final relocation of the Barn to be in front of the existing gate just to the East of its current location? Will a new concrete pad be required for the new location?

Answer: *Bidders shall coordinate with the Owner during the Pre-Construction Conference to find a mutually agreeable location nearby. A concrete pad is not anticipated.*

9. Question: The barn that is to be relocated looks to be in rough condition. There is a potential for it breaking down during the relocation process. We wanted to make the owner aware.

Answer: *Understood. The Bidder will not be held responsible for the pre-existing condition of the mini-barns.*

10. Question: Is there any more detail on the High School electrical outlets that are to be "relocated" in the middle of the courts? HSE will address relocation of the outlets?

Answer: *HSE Facilities will address relocation of existing outlets.*

END OF ADDENDUM 2