

**CITY OF HARTFORD CITY
BLACKFORD COUNTY, INDIANA
PHASE 4 CSO MITIGATION PROJECT
MAY 2026**

Addendum No. 2
May 21, 2026

Bid Date: June 1, 2026 (**Revised**)

Bid Time: 5:00 pm (local time)

Owner: City of Hartford City

Engineer: United Consulting
8440 Allison Pointe Boulevard, Suite 200
Indianapolis, Indiana 46250
Telephone: (317) 895-2585

The following items are a revision/clarification to the requirements of the Contract Bid Documents for this Project. The articles contained in this Addendum take precedence over the requirements of the previously published Contract Bid Documents. Where any article of the Specifications or any detail of the Drawings is modified or deleted by the article contained in the Addendum, the unaltered provisions of that article paragraph, subparagraph, or clause shall remain in effect.

The Bidder must acknowledge receipt of this Addendum by submitting a signed copy with his/her bid package, as well as acknowledgement on page 00300-1 of the Proposal Form. Failure to do so can be cause for bid rejection.

Item No. 1: Information – All questions shall be submitted in writing to United Consulting, Scott Siple, P.E. (scott.siple@ucindy.com) by 12:00 P.M. May 27, 2026. Questions submitted after this time may not be answered prior to bid submission.

Item No. 2: Clarification – AWWA C-905 PVC storm sewer shall be 200 psi, Dimension Ratio (DR) 21 pipe.

Item No. 3: Information – Bidders to acknowledge receipt of this Addendum No. 2 by signing below and attaching the same with bid package. Failure to do so can be cause for bid rejection


Contractor Name

Signature

Date

Title

This Addendum reviewed and approved by:



5/21/2026

A handwritten signature in blue ink that reads "Scott Matthew Siple".

Scott Matthew Siple, P.E.
Reg. Engineer No. 11100304
State of Indiana
Addendum Certification

END OF ADDENDUM NO. 2